

डा० संजीव कुमार यादव

एम० बी० बी० एस०, एम० डी०

जेनरल फिजिशियन
रेफरल रोड, फारबिसगंज



ڈاکٹر ایس۔ کے۔ یادو

Mob. 8809589883, 9709891230

Dr. S.K. Yadav

M.B.B.S. M.D. (Darbhanga)

General Physician

Referral Road, Forbesganj

NOT VALID FOR MEDICO LEGAL PURPOSE

Name Age Sex Add

B.P.

Date 07/05/22

Pulse

Weight

Temp.

To Whome it may Concern

Certified that Sanitary Systems including water supply & Health care of Mittila Public school, R.B. Nagar, Bhadrachar Forbesganj, Dist Araria are maintained in good condition as per requirement & expectation. My Supervision is regular in the school.

07/5/22
Reg No-30917
Bihar Medical Council

नोट :- एक माह पर पुनः फिस लगेगा ।

रविवार को क्लिनिक बंद रहता है।

Letter No. 65 Dated : 26/05/2022

Government of Bihar
OFFICE OF THE EXECUTIVE ENGINEER, PUBLIC HEALTH DIVISION ARARIA.
CHEMICAL AND BACTERIOLOGICAL REPORT OF DRINKING WATER SAMPLES

District Name: -- ARARIA

Month - MAY - 2022

SL. No.	Location of Source	Parameters Examined														Remarks	
		pH	Turbidity	Conductivity	TDS	Total Hardness	Calcium	Magnesium	Chloride	Alkalinity	Iron	Nitrate	Sulphate	Fluoride	Arsenic		Bacteria
1	Mithila Public School, R. B. Nagar, Bhadreswar, Forbesganj, (Araria).	6.9	0.4	129	84	60	12.0	7.29	24	54	0.32	1.1	10	0.14	BDL	-Ve	This Sample is fit for Drinking
Desirable Limit*		6.5-8.5	1.0	-	500	200	75	30	250	200	1.0	45	200	1.0	0.01	-	-
Permissible Limit* in absence of alternate source		NR	5.0	-	2000	600	200	100	1000	600	NR	NR	400	1.5	NR	**	-

Note - (i) Drinking Water Specification Second Revision - IS: 10500: 2012., (ii) BDL means Below Detection Limit., (iii) NR means no relaxation and (iv)** Shall not be detectable in any 100ml sample

Komal
26/05/2022
Chemist
P.H. Division, Araria.

Anwar Kuyal
26/05/2022
Assistant Engineer
P.H. Division, Araria West.

Anwar
26/05/2022
Executive Engineer
P.H. Division, Araria.